

#### **GENERAL NOTE**


A. REFER TO SHEET 137-P001 FOR DRAWING INDEX, LEGEND AND NOTES.


#### ○ NOTES:


- 1 EXISTING TO REMAIN.
- 2 BOX MOUNTED TRANSFORMER LOCATED ABOVE CEILING TO CONTROL SENSOR OPERATED FAUCET ON FIXTURE(S) BELOW. 120V 1PH POWER WILL BE LOCATED IN A WIRING BOX ABOVE THE CEILING BY THE E.C. A 0.75" CONDUIT (FOR LOW VOLTAGE WIRING) STUBBED ABOVE THE CEILING AND EXTENDED DOWN TO AN ELECTRICAL WALL BOX LOCATED BELOW EACH LAVATORY WILL BE PROVIDED BY THE E.C. TRANSFORMER AND LOW VOLTAGE WIRING SHALL BE BY THE P.C. THE P.C. SHALL COORDINATE ALL WORK WITH THE E.C.


3 TRAP PRIMER, REFER TO DETAIL F/137-P601.

- 4 EXTEND NEW 2" DCW & 1 DHW SUPPLY RISERS FROM PIPE BASEMENT BELOW TO ABOVE FIRST FLOOR CEILING TO SERVE RENOVATED AREA AS INDICATED.
- 5 EXTEND NEW 0.75" DHWR PIPING FROM ABOVE FIRST FLOOR CEILING TO PIPE BASEMENT BELOW.
- 6 TYPICAL PATIENT LIFT. COORDINATE PIPING WITH PATIENT LIFT AND ASSOCIATED STRUCTURAL
- 7 EXTEND NEW 2" DCW, 1.25" DHW & 0.75" DHWR SUPPLY RISERS FROM PIPE BASEMENT BELOW TO
- ABOVE FIRST FLOOR CEILING TO SERVE RENOVATED AREA AS INDICATED.
- 8 P.C. SHALL MAKE 0.5" O2, 0.5" MA, & 0.75" MV MEDICAL GAS PIPING CONNECTIONS TO NEW PREFABRICATED BEDSIDE PATIENT UNIT (PROVIDED BY OTHERS). REFER TO SHEET 137-P105 FOR MEDICAL GAS PIPING PLAN. REFER TO DÈTAIL 5 ON ARCHITECTÚRAL SHEET 137-A602 AND SELECTED MODEL FOR EXACT CONNECTION LOCATIONS, CONDITIONS, AND REQUIREMENTS. COORDINATE WORK WITH DIVISION 26 CONTRACTOR.









PARTIAL PIPE BASEMENT - DEDUCT ALT. #6 & #7
Scale: 1/8" = 1'-0"




4" DS BOOT BY P.C.


one-eighth inch = one foot


4" DS BOOT BY P.C.







DEDUCT ALTERNATE PLANS	Hampton VA, VAMC Renovate / Expand SCI, Phase II, 590-911			Date 04/26/2013	Department of Veterans Affairs
				Project No. 590-911  RDC/JPA Project No. 11004.00	
	Building Number 137	Checked RLT	Drawn DPB		Department
d: Project Director	Location			137-P801	
	Hampton, Va.			Dwg. 89 of 135	~










WEST PENTHOUSE SECTION

1/4" = 1'-0"



# 

└─ RELIEF AIR DUCT

L1-48"x88"

RETURN AIR DUCT -

**EAST PENTHOUSE** 

#### GENERAL NOTES


- A REFER TO SHEET 137-M001 FOR LEGEND, ABBREVIATIONS, AND ADDTIONAL GENERAL NOTES.
- B REFER TO AIR HANDLING UNIT DETAIL ON SHEET 137-M503 FOR AH-UNIT LAYOUT AND COMPONENTS.

#### ○ NOTES

- MOUNT UNIT HEATER TO WALL OR STRUCTURE PER MANUFACTURERS RECOMMENDATIONS.
- 2 PROVIDE TYPE B FIRE DAMPER AT FLOOR PENETRATION. REFER TO DETAIL ON SHEET 137-M502. REFER TO SHEET 137-MH101 FOR DUCT CONTINUATION.
- 3 PROVIDE TYPE B FIRE DAMPER AT FLOOR PENETRATION. REFER TO DETAIL ON SHEET 137-M502. REFER TO SHEET 137-
- MH102 FOR DUCT CONTINUATION.
- 4 2.5" CHILLED WATER SUPPLY AND RETURN FROM BELOW. REFER TO SHEET 137-MP102 FOR CONTINUATION.
- 5 1.25" HOT WATER SUPPLY AND RETURN FROM BELOW. REFER TO SHEET 137-MP102 FOR CONTINUATION.
- 6 OUTSIDE AIR INTAKE LOUVER.


DETAIL ON SHEET 137-M504.


- 7 RELIEF AIR LOUVER.
- 8 UNIT SERVICE ACCESS SPACE FOR COIL PULL.
- 9 UNIT TO BE MOUNTED ON 5" CONCRETE EQUIPMENT PAD PER
- 10 AUTOMATIC 2-POSITION RELIEF AIR DAMPER. REFER TO CONTROLS ON SHEET 137-M701.
- 11 LOUVER BY G.C. APPROXIMATE SIZE LISTED. REFER TO
- ARCHITECTURAL PLANS AND ELEVATIONS FOR EXACT SIZE AND LOCATION.
- 12 TRANSITION DUCTWORK TO FULL SIZE OF EQUIPMENT CONNECTION.
- 13 PROVIDE NEW DDC CONTROL PANEL. REFER TO SHEET 137M701 AND SPECIFICATION 23 09 23 FOR ADDITIONAL INFORMATION.
- 14 PROVIDE NEW BUILDING NETWORK AREA CONTROLLER. REFER TO SPECIFICATION SECTION 23 09 23 FOR ADDITIONAL
- 15 EXTEND FULL SIZE DRAIN PIPE TO FLOOR DRAIN. REFER TO AIR HANDLING UNIT TRAP DETAIL ON SHEET 137-M503.
- 16 DUCT MOUNTED SMOKE DETECTOR.
- 17 2" THICK DOUBLE WALL INSULATED PLENUM CASING.
- 18 PROVIDE 3" HIGH CONCRETE CURB BELOW PLENUM CASING.
- 19 18"x60" DOUBLE WALL INSULATED ACCESS DOOR WITH VISION
- 20 DUCT FULL SIZE OF EQUIPMENT CONNECTION.
- 21 PROVIDE FLEXIBLE DUCT CONNECTOR PER DETAIL ON SHEET
- 22 PROVIDE 3" CONCRETE CURB PER DUCT RISER SUPPORTS DETAIL ON SHEET 137-M502.
- 23 PROVIDE DDC DIFFERENTIAL PRESSURE SENSOR BETWEEN THE CHILLED WATER SUPPLY AND RETURN PIPING AT THIS
- 24 PIPE COILS PER DETAILS ON SHEET 137-M503.
- 25 4" CHILLED WATER SUPPLY AND RETURN FROM BELOW. REFER TO SHEET 137-MP102 FOR CONTINUATION.
- 26 2" HOT WATER SUPPLY AND RETURN FROM BELOW. REFER TO SHEET 137-MP102 FOR CONTINUATION.
- 27 PROVIDE DDC DIFFERENTIAL PRESSURE SENSOR BETWEEN THE HOT WATER SUPPLY AND RETURN PIPING AT THIS LOCATION.
- 28 PROVIDE MANUAL AIR VENT IN PIPE DROP.
- 29 PROVIDE 3" HIGH CONCRETE CURB AROUND PIPING THRUOOR.
- 30 CONSTRUCT DUCT IN REMOVABLE SECTIONS.
- 31 SUPPORT DUCT OFF FLOOR.



5 EAST PENTHOUSE SECTION


1/4" = 1'-0"





Revisions


Date




 RIGID STRAIGHT TERMINAL UNIT INLET LENGTH SHALL BE A MINIMUM OF 3 TIMES THE DIAMETER OF INLET SO AS TO ACHIEVE ACCURATE AIRFLOW SENSOR READINGS.

- 2. A FLEXIBLE AIR DUCT CONNECTOR IS NOT MANDATORY FOR INLET TO THIS BOX, BUT ALLOWED TO ACCOMMODATE MINOR OFFSETS. MAXIMUM LENGTH 3'-0"
- 3. PROVIDE DUCT TRANSITION WHERE SCHEDULED DUCT RUNOUT SIZE TO UNIT IS DIFFERENT THAN TERMINAL UNIT INLET SIZE.
- 4. FLEXIBLE AIR DUCT CONNECTORS, WHEN USED FROM TERMINAL UNIT SUPPLY AIR DUCT TO DIFFUSER, SHALL NOT EXCEED 5'-0". USE RIGID ELBOWS FOR CHANGE OF DIRECTION GREATER THAN 45°.
- 5. COMPONENT ARRANGEMENT MAY VARY BY MANUFACTURER. PROVIDE INSULATION W/VAPOR BARRIER FOR CONNECTING DUCT SECTIONS.
- 6. PROVIDE SOUND ATTENUATOR IF REQUIRED TO MEET DESIGN ROOM NC. PROVIDE DUCT TRANSITION BETWEEN TERMINAL UNIT AND SOUND ATTENUATOR WHERE ATTENUATOR SIZE DIFFERS FROM TERMINAL UNIT OUTLIET SIZE
- 7. DUCT RUNOUT TO DIFFUSERS SHALL BE SAME SIZE AS THE DIFFUSER NECK SIZE UNLESS OTHERWISE NOTED.

## **DUCT CONNECTIONS-AIR TERMINAL UNITS**




## FLEXIBLE AIR DUCT CONNECTOR




#### NOTES

- ALL VANE ELBOWS SHALL BE CONSTRUCTED AND INSTALLED AS DETAILED BY
- 2. WHEN W1 DOES NOT EQUAL W2, VANE SHALL BE SINGLE THICKNESS VANE TYPE REGARDLESS OF W DIMENSION.
- 3. ALL SINGLE THICKNESS VANES SHALL HAVE A 2" RADIUS, 1 1/2" MAXIMUM SPACE BETWEEN VANES AND A 3/4" TRAILING EDGE.
- WHEN W EQUALS W2 AND W1 IS GREATER THAN 20", VANES SHALL BE DOUBLE VANE TYPE.

## **DUCTWORK SQUARE VANE ELBOWS**




RECTANGULAR FLEXIBLE CONNECTION




ROUND FLEXIBLE CONNECTION

# FLEXIBLE DUCT CONNECTIONS



DUCTWORK TRANSITIONS

NOTE:
UNLESS OTHERWISE INDICATED ON PLANS, MAXIMUM ANGLES SHOWN SHALL APPLY.




- 1. THE INTERIOR SURFACE OF ALL RADIUS ELBOWS SHALL BE MADE ROUND.
- ALL STANDARD RADIUS ELBOWS CAN BE SUBSTITUTED WITH SHORT RADIUS ELBOWS. ALL SHORT RADIUS ELBOWS SHALL HAVE VANES. VANES SHALL BE CONSTRUCTED, SUPPORTED AND FASTENED AS RECOMMENDED BY SMACNA.

WITH ONE VANE


# **DUCTWORK RADIUS ELBOWS**

WITH TWO VANES




MAIN EXHAUST OR RETURN

# EXHAUST OR RETURN RANCH DUCTWORK




SUPPLY DUCT TAKEOFF - AIR TERMINAL UNITS




THE BRANCH DUCT TAKE-OFF MAY BE USED FOR UP TO 15% OF THE MAIN DUCT CFM ANYTIME, AND UP TO 40% WHEN THE MAIN DUCT VELOCITY IS 1000 FPM OR LESS. THE AIR SPLIT DUCT TAKE-OFF SHALL BE USED IN ALL OTHER CASES


## SUPPLY DUCTWORK TAKE-OFFS



ALTERNATE SUPPLY DUCT
TAKEOFF - AIR TERMINAL UNITS



# RETURN OR EXHAUST GRILLE/REGISTER CONNECTION



Date



Heapy Project No.: <u>2011-04008</u>

